

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO DATED: 107 /camp / Lab -1

Date - 13/08/25

It is certified that an inspection team headed by Assistant Engineer, Shashank Pandey from U.P. Jal Nigam Gorakhpur inspected the Ratna Memorial Public School, P.O.- Arogya mandir, Gorakhpur, Pin Code-273003 on 08/08/2025 and on the basis of Water Test Report (Attached) bearing no 107camp/lab-1 dated 13/08/2025 of District Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that the Ratna Memorial Public School, P.O.- Arogya mandir, Gorakhpur, Pin Code-273003 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till: 13/08/2025 to 12/08/2026

Vishal Prasad

S. Pandey

Name:- Shashank Pandey
Assistant Engineer

10th Division, U.P. Jal Nigam
GORAKHPUR

Designation:- Assistant Engineer

To,

Manager

Ratna Memorial Public School,

P.O.- Arogya mandir,

Gorakhpur, Pin Code-273003

[Signature]

MANAGER
RATNA MEMORIAL PUBLIC SCHOOL
RATNA PRAKASH MARG, AROGYA MANDIR
GORAKHPUR

[Signature]

PRINCIPAL
RATNA MEMORIAL PUBLIC SCHOOL
RATNA PRAKASH MARG, AROGYA MANDIR
GORAKHPUR



Regional Water Testing Laboratory (Uttar Pradesh Jal Nigam, Gorakhpur)

Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road,
Gorakhpur(U.P)-273003



TC-12931

CHEMICAL SAMPLE TEST REPORT

Rept. No	07 /Camp / Lab-1	Date:	13/08/2025	Page No	
Customer Details					
Office Name and Address	Ratna Memorial Public School (RAMPUS), Ratna Prakash Marg P.O.-Arogya Mandir Gorakhpur				
Ref Letter No & Date	08/08/2025				
Basic details of sample					
District	Gorakhpur	Block	--		
Gram Panchayat	--	Village	--		
Habitation	--	Location	Ratna Prakash Marg P.O.-Arogya Mandir Gorakhpur		
Water Source	R.O.	Sample Code	(C/25/08/06)		
Quantity of Sample	1000ml	Date of S.C.	08/08/2025		
Receiving Date	08/08/2025	S. Collector	Faiz Ahmad		
Sample Depositor	Faiz Ahmad				
Analysis Start Date	11/08/2025	Analysis Completion Date	11/08/2025		

Environmental Condition

Temperature	25.8 °C	Relative Humidity	54%
-------------	---------	-------------------	-----

Technical Data of Analysis


Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	Agreeable				IS 3025 (Part 5):2018
2	Turbidity	0.35	NTU	1	5	IS 3025 (Part 10):2023
3	pH (25°C)	7.29	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
4	Total Dissolved Solids	98	mg/L	500	2000	IS 3025 (Part 16) :2023
5	Total Hardness	52	mg/L	200	600	IS 3025 (Part 21) :2023
6	Total alkalinity	66	mg/L	200	600	IS 3025(Part 23):2023
7	Chloride as Cl	16	mg/L	250	1000	IS 3025(Part 32);2003
8	Calcium	12.8	mg/L	75	200	IS 3025(Part 40): 2024
9	Magnesium	4.87	mg/L	30	100	IS 3025(Part 46): 2023
10	Sulphate	2.032	mg/L	200	400	APHA 24th Edition 4500-SO, Method E. Turbidimetric Method 2023
11	Nitrate	0.062	mg/L	45	No relaxation	APHA 24th Edition 4500-NO3 Method B UV Screening Method 2023
12	Iron	0.013	mg/L	1	No relaxation	APHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
13	Fluoride	0.180	mg/L	1.0	1.5	APHA 24th Edition 4500-F Method C (Electrode Method) :202300
14	Arsenic	BDL	mg/l.	0.01	No Relaxation	APHA 24th Edition 3500 Method B (Silver Diethyldithiocarbamate Method)

#BDL- Below Detection Limit, NA- Not Analyzed

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.
 5. Sample not collected by the laboratory.


Review By


 P. Pandey
 Assistant Engineer
 Authorized Signatory
 Gorakhpur

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

-----End of Report-----


PRINCIPAL
 RATNA MEMORIAL PUBLIC SCHOOL
 RATNA PRAKASH MARG, AROGYA MANDIR
 GORAKHPUR


MANAGER
 RATNA MEMORIAL PUBLIC SCHOOL
 RATNA PRAKASH MARG, AROGYA MANDIR
 GORAKHPUR



Regional Water Testing Laboratory,
(Uttar Pradesh Jal Nigam, Gorakhpur)

Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road, Gorakhpur(U.P)-273003

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	107 /Camp / Lab-1	Date:	13/08/2025	Page No	1/1
Customer Details					
Office Name and Address	Ratna Memorial Public School (RAMPUS), Ratna Prakash Marg P.O.-Arogya Mandir Gorakhpur				
Ref Letter No & Date	08/08/2025				
Basic details of sample					
District	Gorakhpur	Block	--		
Gram Panchayat	--	Village	--		
Habitation	--	Location	Ratna Prakash Marg P.O.-Arogya Mandir Gorakhpur		
Water Source	R.O.	Sample Code	(C/25/08/06)		
Quantity of Sample	500ml	Date of S.C.	08/08/2025		
Receiving Date	08/08/2025	S. Collector	Faiz Ahmad		
Sample Depositor	Faiz Ahmad				
Analysis Start Date	11/08/2025	Analysis Completion Date	13/08/2025		

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (25°C ± 2°C)	7.29		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 (PART 26) : 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 rd Edition :2017
4	E .Coli	0	CFU	0	CFU	APHA 23 rd Edition :2017

Result : Satisfactory

Remark: Potable

- Note 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of tests reports unless.

Sandhya Veerna
Analysed By

Sandhya Veerna
Authorized Signatory

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

-----End of the Report-----

Raj Kumar
PRINCIPAL
RATNA MEMORIAL PUBLIC SCHOOL
RATNA PRAKASH MARG, AROGYA MANDIR
GORAKHPUR

[Signature]
MANAGER
RATNA MEMORIAL PUBLIC SCHOOL
RATNA PRAKASH MARG, AROGYA MANDIR
GORAKHPUR